

No: 11/2022-2023

01-07-2022
Vallithode

Sanitation Certificate


Sub : Regarding issue of No Objection Certificate in respect of pollution free environments .

Sir / Madam,

It is hereby declared that **Benhill English School** (affiliation no 930593 school code 75678), Iritty ,Kannur, kerala, 670703, is located in and around the best neat and clean sanitary conditions and has healthy environments.

Truly,

Health Inspector



Primary Health Centre

HEALTH INSPECTOR
PRIMARY HEALTH CENTRE
VALLITHODE,
Ph: 0490 2421232

Vallithode, Kannur.



KERALA WATER AUTHORITY
QUALITY CONTROL DISTRICT LAB, THANA, KANNUR
WATER ANALYSIS REPORT



TC-9558

Tele phone No : 0497 2704380
email : kwaqclabkannur@gmail.com

ULR-TC955822000000896F

Report No - KWA/QA/R/06/89/1/56/174	Date : 06/06/2022
Customer Name and Address	1. Date of receipt : 03/06/2022
Benhill English School, Iritty	2. Sampling provided by Customer
Benhill, Iritty (P O)	3. Sample Code : 07/22 (10)
(NON DOMESTIC PURPOSE)	4. Source of Sample : Open Well
	5. Sample quantity : 1 lit
	6. Test performing dates
	From : 03/06/2022 To : 03/06/2022

Sl No	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500-2012	Result
1	Taste		IS 3025 (Part 8)	Agreeable	-
2	Colour	HAZEN	IS 3025 (part 04) -1983 (Reaffirmed 2017)	5	BDL
3	Odour		IS 3025 (part 5) -2018	Agreeable	Agreeable
4	Turbidity	(NTU)	IS 3025 (part 10) -1984 (Reaffirmed 2017)	1	0.09
5	pH		IS 3025 (part 11) -1983 (Reaffirmed 2017)	6.5 to 8.5	7.35
6	Total Alkalinity (as CaCO ₃)	(mg/litre)	IS 3025 (part 23) -1986 (Reaffirmed 2019)	200	28.0
7	Total Dissolved Solids (TDS)	(mg/litre)	IS 3025 (part 16) -1984 (Reaffirmed 2017)	500	42.00
8	Total Hardness (as CaCO ₃)	(mg/litre)	IS 3025 (part 21) -2009 (Reaffirmed 2019)	200	6.00
9	Calcium (as Ca)	(mg/litre)	IS 3025 (part 40) -1991 (Reaffirmed 2019)	75	0.80
10	Magnesium (as Mg)	(mg/litre)	IS 3025 (part 46) -1994 (Reaffirmed 2019)	30	0.97
11	Chloride (as Cl)	(mg/litre)	IS 3025 (part 32) -1988 (Reaffirmed 2019)	250	5.79

Remarks:

The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the laboratory

Authorised By

Rekha V K

Sr. Sanitary Chemist

* End Of Report*

SR. SANITARY CHEMIST
QUALITY CONTROL
KERALA WATER
KANNUR
Rev Date: 01.06.2021

Issue No: 02

Issue Date: 01.06.2021

Rev Date: 01.06.2021

Issue No: 001

Issue Date: 01.06.2021